



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/06/2025

Area: IOSA

Equipment	Job
MISC	TWO CHAIN PULLEY DEFECTS RECTIFIED AND MADE READY FOR USAGE.
ELECTRICAL SHED	HOUSE KEEPING IS IN PROGRESS
MISC	55KW SPARE MOTOR OF OC-37A , MEGGERED AND TRIAL RUN IS IN PROGRESS.
ELECTRICAL HOISTS	WORKING STATUS CHECKED AND DEFECTS RECORDED FOR HOISTS AT OC-11A, OJH-8A, OJH-5A,OC-7C HEAD and TAIL END , OC-7A H/E.
OC-3A	PPM DONE ON MOTOR AND FIELD DEVICES