



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 05/06/2025

Area: CHP

Equipment	Job
CC 43/44 tunnel	Air blower fan motor freed and kept running
CC 41,45,125 tunnel	9 nos LED lamp fixtures replaced ,ckt problems rectified and improved lighting
SCR 1,SCR 7	30* and slew limits ckt problems rectified and kept in ckt tested
CC 25	Electronic OLR replaced and tested
CC 43	PPM was done
CC 41,42 tunnel	Air blower found burnt