



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/07/2025

Area: OHP

Equipment	Job
co-47 h/e hoist	hoist up contactor replaced and tested operations.
co-43a	panel and cjb dressing is done.
co-14a,14b,13a,rsco-6a,vf-8a,9a,10a,15a,16a,17a,18a,19a,20a,21a,22a,23a,24a,25a,26a,27a,28a,29a,30a,31a,32a,33a,34a,35a,36a,37a,38a,39a,40a,41a,42a,43a,44a,45a,46a,47a,48a,49a,50a,51a,52a,53a,54a,55a,56a,57a,58a,59a,60a,61a,62a,63a,64a,65a,66a,67a,68a,69a,70a,71a,72a,73a,74a,75a,76a,77a,78a,79a,80a,81a,82a,83a,84a,85a,86a,87a,88a,89a,90a,91a,92a,93a,94a,95a,96a,97a,98a,99a,100a	motor and feeder side ppm is done
wbr-1 on co-26	boom conveyor on and hooter on PB replaced.
co-26	new brs is installed and restored in circuit.
JHO-3 AND JHO-2	hoist ppm is done
JH O-2 Ldb	fuses blown replaced and lighting is restored.
co-5,6,7,1a	beltsways checking is done , all are found to be in circuit.,
rsco-9a	motor and feeder side ppm is done
brc-3	shifted from co-8a to co-30