



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 19/02/2026

Area: CHP

| Equipment       | Job  |
|-----------------|--|
| RG ground floor | Cable tray cleaning underprogress                                |
| CC 106 on SCR 6 | Material stacking started from GPL after checking the interlocks |
| CC 221          | Output contactor C2 replaced and termination done                |