



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/11/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-29	REPORTED STOPPING ON ZSS FOUND JAMMING	INFORMED TO OPERATION	06:30:00	06:40:00	
2	OHP	CO-26	OLR ACTED	RESET DONE	07:00:00 08:50:00	07:10:00 09:00:00	
3	OHP	VS-4A	REPORTED NOT HEALTHY E/STOP ACTED	RELEASED	10:55:00	11:00:00	
4	OHP	BRC ON CO-28	REPORTED ALL DRIVES ARE NOT RUNNING MECHANICAL S/D	AFTER MECHANICAL CLEARANCE S/D NORMALISED THAN OK	10:40:00	11:00:00	
5	CHP	CC-113A	OLR ACTED	RESET DONE	12:05:00	12:15:00	
6	CHP	CC-32 R-1	LUFFING NOT WORKING DOWN LIMIT ACTED	RELEASED THAN OK	06:30:00	06:55:00	
7	CHP	CC-32 R-1	B/ C STOPPING ON ZSS FOUND INTER LOCK CAGE STUCK UP WITH COAL PIC(2TIMES)	REMOVED	08:15:00 10:30:00	08:30:00 10:45:00	
8	CHP	CC-38 SCR-6	LT NOT TAKING PLACE DRIVE TRIP DUE TO TRACK JAMMING	AFTER CLEAR THE TRACK THAN DRIVE RESET DONE	09:00:00	09:42:00	
9	CHP	CC-39 SCR-2	LT NOT TAKING PLACE O/T ACTED	RELEASED THAN OK	09:20:00	09:30:00	
10	CHP	CC-47	STOPPING ON ZSS FOUND ZSS CAGE STUCK	REPLACED WITH NEW CAGE THAN OK	11:25:00	11:55:00	
11	CHP	CC-38 SCR-6	B/C NOT RUNNING JAMMING	INFORMED TO OPERATION	12:00:00	12:30:00	
12	CHP	CC-47	C/S NOT RESET	SENSOR CLEANING THAN OK	13:40:00	13:55:00	
13	WT	CP-3	DRIVE -3 OLR ACTED	RESET DONE	11:00:00	11:20:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OT-5	NOT MOVE	POWER RE-CYCLED THAN OK	12:00:00	12:10:00	
15	WT	AF-2	TRIPPED ON OLR DUE TO JAMMING	AFTER CLEAR THE JAMMING RESET DONE	13:00:00	13:30:00	