



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/01/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	14:30:00	14:40:00	
2	OHP	CO 21	ZSS PROBE CABLE GOT CUT	REJOINT	15:30:00	15:45:00	
3	OHP	WBR ON CO 29	LT DOWN LIMIT ACTED	BYPASSED AND LIFTED THEN ALL DRIVES OK	18:15:00	18:30:00	
4	CHP	CC 52	FEEDING CONVEYOR MPD ACTED	RESET	18:05:00	18:10:00	
5	CHP	CC 23	ZSS PROBE CABLE GOT CUT	REJOINT THEN OK	18:46:00	18:55:00	
6	CHP	SCR 6 ON CC 39 LT	DRIVE TRIP	RESET	17:05:00 19:10:00	17:15:00 19:20:00	
7	CHP	S2 ON CC 36	OLR ACTED	RESET	20:55:00	21:05:00	