



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/06/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on 34	CT not taking place,end limit acted operator cabin side	limit released	23:55:00	00:10:00	
2	OHP	WOBR on CO 6A	no power,ACB is in off	ACB made on	02:20:00	02:40:00	
3	CHP	CC 32 SCR 5	LT not taking place,M2 mpcb trips	made it on	01:00:00 23:00:00	01:10:00 23:10:00	
4	CHP	cc 131	motor trips in olr	reset	23:22:00	23:27:00	2 times
5	CHP	CC 51	motor trips in olr	reset	00:25:00	00:30:00	
6	CHP	CC 31 flap gate motor	trips in olr	reset	01:40:00	01:50:00	