



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/01/2026

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------------------------|---|------------------------------|----------------------|----------------------|---------|
| 1 | OHP | CO 12 ZSS | PROBE GOT CUT | REJOINT | 07:20:00 | 07:30:00 | |
| 2 | CHP | CC 114 | OLR ACTED | RESET | 07:20:00 | 07:20:00 | |
| 3 | CHP | CC 51 | FEEDING CONV MPD ACTED | RESET | 11:55:00 | 13:40:00 | 3 TIMES |
| 4 | CHP | SCR 6 ON CC 39 | LT M2 TRIPPED | MADE IT ON | 12:50:00 | 13:00:00 | |
| 5 | CHP | SC R6 ON CC 39 B/C | OLR ACTED | RESET | 13:30:00 | 13:40:00 | |
| 6 | CHP | CC 131 HEALTHY STOPPING | AUXILLARY CONTACK BLOCK LOOSE | TIGHTENED | 11:00:00 | 11:15:00 | |
| 7 | WT | OT2 | D2 TRIPPED ON PGF1 | RESET | 08:00:00 09:30:00 | 08:05:00 09:35:00 | |
| 8 | WT | OT4 | CLAMP LIMIT SWITCHES HIGH MISSING DUE TO CORE PROBLEM | SPARE CORE CONNECTED THEN OK | 13:45:00 | 13:55:00 | |