



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 03/12/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 21	ZSS CAGE PROBLEM	REPLACED	00:30:00	01:00:00	
2	OHP	CO 11A ZSS	PROBE DISTANCE ADJUSTED	THEN OK	00:30:00	00:50:00	
3	OHP	CO 44 TIS	POWER MPCB TRIP	MADE IT ON	00:00:00	00:15:00	
4	OHP	CO 84	OLR ACTED	RESET	23:20:00	23:30:00	
5	CHP	SCR 10 ON CC 105 LT	PCRD CABLE FELL DOWN	WINDING DONE	00:45:00	01:05:00	
6	CHP	SCR 4 ON CC 31	B/C BURNT MOTOR REPLACED	CHECKED AND GIVEN CLEARENCE	22:00:00	23:30:00	
7	CHP	CC 51	FEEDING CONV MPD ACTED	RESET	23:30:00	04:45:00	12 TIMES
8	CHP	CC 54	OLR ACTED	RESET	00:45:00	02:30:00	6 TIMES
9	CHP	SCR 8 ON CC 112	PCRD CABLE CAME OUT OF HT COUPLER	INFORMED TO DNW	05:30:00	06:00:00	
10	CHP	SCR 3 ON CC 35	LT DRIVE TRIPPED	RESET	04:15:00	04:25:00	
11	CHP	SCR 4 ON CC 31 LUFF	OIL LEVEL LOW	INFORMED TO MECH	00:25:00	00:40:00	
12	IOSA	BRC ON OC 15A	CT LIMIT LEVER BROKEN	REPLACED THEN OK	03:15:00	03:30:00	