



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 14/11/2025

Area: OHP

Equipment	Job
tbs-2	shifted from repair bay to co-20 and trail run taken.,
co-65 totaliser	seperate totaliser is made for different materials being sent on operation requirement and indicated in OCR HMI
1-14lc4 ; 1-14lc3 ; 1-14lc7 ; 1-14lc8 ; 1-14lc4	incomers are normalized and bus couplers are made off.
jh o-14,bpc-1,bpc-2,28,27a,30a,8a,db-1	pdb's; ldb's ppm is done
bpc-1,bpc-2	motor , panel and safety devices ppm is done
co-12a gallery	lighting is improved and circuit rectification is done.
co-10a,rsco-1a,rco-6a,vf-1a,2a, bf-1a,2a,3a,4a,5a,7a,8a,9a ; vs-1a to vs-5a	motor and panel side ppm is done;
co-14a,14b,13a,rsco-6a,vf-8a,9a,10a,10a,10a, co-41a,42a,43a	motor and panel side ppm is done
co-1a side sump pump ; and tunnel gallery lighting	maintenance is done
brc on co-28	m4 motor failed, is shifted to hvmmc-1
tbs-6	shifted from co-20 to co-7a ; m1 failed motor is removed and shifted to hvmmc-1
co-58, rsco-9a	motor and panel side ppm is done
co-30	spare mccb module with schnider 250a mccb prepared is racked in and trail run taken,