



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/07/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT 4 ON BYPASS 2	CHUTE POSITION SIGNAL LOOSE IN SENSOR TERMINATION/ TIGHTENED	CHUTE POSITION SIGNAL KEPT IN CKT	15:30:00	16:30:00	
2	CHP	CC 29	TRIPPED ON OLR 2 TIMES	RESET DONE	15:50:00	16:00:00	
3	CHP	SCR 9 ON CC104	bc signalmissing	LT DONE THEN OK	16:30:00	16:45:00	