



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR acted	reset	16:12:00	16:20:00	
2	OHP	TBS on CO 22	LT not moving	Break problem, informed to mechanical	17:25:00	17:35:00	
3	OHP	CO 87	OLR acted	reset	19:30:00	19:40:00	
4	OHP	WOBR on CO 25	LT not working	Drive tripped , reset done	20:00:00	20:20:00	
5	OHP	BRC on CO 8A	BC not running	Emergency acted , released	21:00:00	21:15:00	
6	OHP	WOBR on CO 25	LT not moving	M-3 tripping . M-3 disconnected and tested , ok	21:00:00	21:25:00	
7	OHP	TBS on CO 22	LT not working due to pcrd overtension	overtension released	21:30:00	21:45:00	
8	OHP	TT 1	Not moving	MPCB tripped , made on	15:40:00	15:50:00	
9	CHP	CC 105 , SCR 10	Operator cabin adjustment required from operation	Adjustment done	14:30:00	14:45:00	
10	CHP	CC 32 , SCR 5	BC not running	OLR tripped , reset done	17:00:00	17:20:00	
11	CHP	CC 111 , S-3	BC signal missing	LT done	19:30:00	19:45:00	
12	CHP	CC 34 , SCR 2	LT not working due to PCRD overtension	Overtension released	20:00:00	20:20:00	
13	CHP	CC 131	Tripped on overload (3 times)	reset	17:35:00	21:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 51	Stopped on ZSS bcz of material overload	Informed operation for cleaning	17:15:00	17:25:00	
15	CHP	CC 21 Carriage drive	Tripped on overload	reset	17:30:00	17:40:00	
16	CHP	CC 29	Flap gate motor tripped	reset	21:00:00	21:10:00	
17	CHP	CC 20	ZSS cage got reversed	cage adjusted properly	21:35:00	22:00:00	
18	WT	OP 2	Not moving	D 5 tripped , reset done	15:50:00	16:00:00	
19	IOSA	L and T WOBR	LT not taking place	LT limit acted , reset done	15:20:00 20:00:00	15:40:00 20:20:00	