



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/01/2026

Area: OHP

Equipment	Job
rsco-1a belt drive removed 22kw, 180L, 4 pole motor	coupling is removed and sent for overhauling
tbs-2 on co-20	ht coupler and slip ring ppm is done.
co-6	motor and panel side ppm is done
tbs-1 on co-22 ; wob-3 on oc-29	ppm is done