



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/09/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 11 CARRIAGE DRIVE	MPCB TRIPPED	MADE IT ON	04:00:00 23:00:00	04:15:00 23:10:00	
2	OHP	TT4 LT	MPCB TRIPPED	MADE IT ON	03:30:00	03:45:00	
3	OHP	CO 9	OLR ACTED	RESET	22:05:00	22:15:00	
4	OHP	WBR ON CO 26	SLEW DRIPPED	RESET	22:40:00	22:55:00	
5	CHP	SCR 7 ON CC 37	PCRD OLD CABLE JOINT GOT OPENED	INFORMED TO DNW	00:00:00	06:00:00	
6	CHP	SCR 8 ON CC 112 LUFF	OIL LEVEL LOW	AFTER FILLING OIL THEN OK	02:45:00	03:00:00	
7	CHP	SCR 5 ON CC 32 LT	O/T ACTED DUE TO CABLE ZIG ZAG	RELEASED AND PROPERLY WINDING DONE	23:40:00	00:15:00	
8	CHP	CC 31	OLR ACTED	RESET	01:50:00	02:00:00	
9	CHP	SCR 1 ON CC 36	B/W OLR ACTED	RESET	02:00:00	02:20:00	
10	CHP	LC 19	FEEDER 1 TRIPPED	MADE IT ON	22:50:00	23:00:00	
11	CHP	CC 51	FEEDING CONVEYOR OLR TRIPPED 8 TIMES	RESET	00:00:00	06:00:00	