



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/02/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-51(C/D)	Reported tripped	OLR acted.Reset done	23:00:00	23:10:00	
2	OHP	TBS on CO-21	B/C stopping on ZSS	Wrong complaint	00:00:00	00:15:00	
3	OHP	Vf-19	Reported tripped	M-1 tripped.Reset done	00:00:00	00:10:00	
4	OHP	Co-20	Reported ZSS acting	Belt snapped	01:10:00	01:20:00	Informed to operation
5	CHP	CC-51	MPD tripped	Reset done (7 times)	23:00:00	05:15:00	
6	CHP	CC 132	Reported not healthy	P/C found acted.Reset done	04:30:00	04:35:00	
7	CHP	CC-106 SCR-6	LT not running	Fault reset done at cabin and tested okay	00:30:00	00:45:00	
8	CHP	CC-34 SCR-1	B/C not running	Wrong complaint	04:00:00	04:10:00	