



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 19/08/2025

Area: WT

Equipment	Job
CP 3	D2 motor changing and testing done with New motor ,stator cantactor kit replacd
OP 4 and 6	After rake maintenance done