



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/12/2025

Incharge(s): Amit Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|-----------------------|--|----------|----------|-------------------------|
| 1 | OHP | BRC on CO-32 | B/C not running | E-PB acted.Released and tested okay | 16:20:00 | 16:25:00 | |
| 2 | OHP | CO-21 | ZSS cage got reversed | Repositioned | 19:10:00 | 19:25:00 | |
| 3 | OHP | TBS on CO-21 | LT not working | M-2 tripped.Made on | 19:25:00 | 19:40:00 | |
| 4 | CHP | CC-54 | Reported tripped | OLR acted.Reset done(3 times) | 16:54:00 | 20:16:00 | |
| 5 | CHP | Cc-51 | MPD acted | Feeding conveyor stopped.Reset done | 20:16:00 | 20:20:00 | |
| 6 | CHP | VS-3 | Reported Tripped | OLR acted due to jamming | 18:30:00 | 18:40:00 | |
| 7 | CHP | CC-32 | Reported tripped | OLR acted.Reset done | 15:00:00 | 15:10:00 | |
| 8 | CHP | Cc-33 SCR-5 | Lt not taking place | Drive tripped.Reset done | 16:30:00 | 16:40:00 | |
| 9 | CHP | Cc-38 SCR-6 | B/C not running | MPCB tripped.Motor meggered and found burnt. | 18:10:00 | 22:30:00 | Replacement is going on |
| 10 | CHP | CC-34 SCR-1 | Skew not taking place | Limit acted due to coal jamming. | 20:00:00 | 20:10:00 | Informed to operation |
| 11 | CHP | CC-43 | Reported tripped | OLR acted.Reset done | 20:30:00 | 20:40:00 | |
| 12 | WT | OP-5 | Reported not moving | D5 tripped.Reset done | 14:20:00 | 14:30:00 | |
| 13 | WT | OC-1A | Reported tripped | OLR acted.Reset done | 21:05:00 | 21:10:00 | |
| 14 | IOSA | OC-7B | Reported ZSS acting | Cage stuck up with stone.Removed | 14:35:00 | 14:45:00 | |