



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/11/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO 6A	interlock ZSS cage stucked	cage replaced	22:30:00	23:00:00	
2	OHP	CO 29	olr acted	reset	01:25:00	01:35:00	
3	OHP	Co 26	olr acted	reset	00:50:00	01:00:00	
4	OHP	WOBR on co 25	slew not working,olr acted	reset	23:30:00	23:45:00	
5	OHP	BRC on cO 28	LT not working properly,brake problem,brake wire cut at M2	brake wire jointed,HRC fuse replaced	23:10:00	23:30:00	
6	CHP	CC 15	ZSS acted,mech gear box problem	informed mechanical	04:00:00	04:10:00	
7	CHP	CC 51	mpd tripped 2 times	reset	03:10:00	03:20:00	
8	CHP	CC 54	olr acted	reset	22:50:00	22:55:00	
9	CHP	CC 126	helathy stop,belt full jammed,stopped in ZSS	informed operation	02:30:00	03:00:00	
10	CHP	CC 39 SCR 2	LT not working,Ot acted	OT released	00:30:00	04:05:00	4 times ,TO be checked in G shift
11	CHP	CC 32 R1	PCRd cable fallen	cable rewinding done	22:00:00	23:00:00	
12	CHP	CC 125	Motor tripped,OLr	reset	04:55:00	05:00:00	3 times
13	CHP	CC 125	motor not rotating	checking going on	05:55:00	06:05:00	
14	WT	OT `1	d1 tripped in pgf1 fault	reset done	03:30:00	03:35:00	
15	WT	OP9	no movement	reset done in system	02:15:00	02:17:00	