



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/10/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-22	C/S NOT HEALTHY	SENSOR CLEANED THAN OK	15:10:00	15:20:00	
2	OHP	CO-51	TRIPPED ON OLR	RESET DONE	17:20:00	17:30:00	
3	OHP	TBS ON CO-20	R/LUFF NOT TAKING PLACE MPCB TRIP	MADE ON	17:20:00	17:40:00	
4	OHP	CO-58	TRIPPED ON OLR	RESET DONE	19:30:00	19:45:00	
5	OHP	CO-34	TRIPPED ON OLR	RESET DONE	20:30:00	20:40:00	
6	OHP	CO-29	TRIPPED ON OLR	RESET DONE	20:50:00	21:00:00	
7	CHP	CC-104 SCR-9	SLEW NOT WORKING FOUND POWER MCCB TRIP	MADE ON THAN OK	15:35:00	15:45:00	
8	CHP	CC-28 TT	POSITION INDICATION NOT SHOWING ON CC-31 CHECKED AND FOUND GLASS FUSE BLOWN IN I/O RACK	GLASS FUSE REPLACED THAN OK	15:20:00	15:40:00	
9	CHP	CC-54	TRIPPED ON OLR (2TIMES)	RESET DONE	21:35:00 21:55:00	21:45:00 22:00:00	
10	WT	OT-1	DRIVE-1 TRIP (PGF-1) FAULT	RESET DONE	20:00:00	20:10:00	
11	WT	OT-3	POWER SUPPLY TRIP IN BRAKE PANAL CHECKED AND FOUND 2NOS DIODES FAILED	REPLACED WITH NEW BRIDGE	15:00:00	15:30:00	
12	WT	OT-4	F/LIMIT GOT STUCK UP	MADE IT FREE THAN OK	20:30:00	21:00:00	