



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/05/2025

Area: CHP

Equipment	Job
CC 54	Removed motor sent to ERS
JH C3	LDB incoming MCB replaced
CC 25/26 Take up	Lighting improved
CC 15,19,22,113,132	PPM was done
CC 104 SCR 9	PCRD OT kept in ckt
R/Bay Stacker	Upper MCC to lower MCC power and control cables removed for mechanical job