



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/01/2026

Area: OHP

Equipment	Job
tbs-7 on co-19	left luff motor failed, replacement is under process.
cbms-4a on co-2a	local trail run is taken and restored in circuit.
co-14	motor and panel side ppm is done
co-2,3,4,sco-1a hmi pop-up	TIS run feedback indication is provided.