



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/10/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-14	OLR ACTED(2TIMES)	RESET DONE	11:50:00	12:10:00	
2	OHP	TBS ON CO-7A	R/LUFF NOT TAKING PLACE FOUND NO LUFF MOTER INFORM TO G,SHIFT	G, SHIFT ATTEND THE PROBLEM	11:40:00	12:00:00	
3	CHP	CC-51	MPD OLR ACTED (10)TIMES DUE TO FEEDING CONVEYOR STOP	RESET DONE	06:30:00	11:00:00	
4	CHP	CC-111 S-3	LT NOT TAKING PLACE FOUND PCRD O/T ACTED	RELEASED	06:40:00	06:55:00	
5	CHP	CC-112 SCR-8	B/W NOT RUNNING FOUND WRONG OPERATION CP PROBLEM	INFORMED TO MECHANICAL	08:50:00	09:30:00	
6	CHP	CC-34 SCR-2	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	08:15:00	08:25:00	
7	CHP	CC-37 SCR-7	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	09:20:00	09:30:00	