



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 21/05/2025

Area: OHP

Equipment	Job
CO-6A BRS	electronic brs bypassed due to sensors problem, JOD is in circuit.
om-16,12,10,lc-6,OM-9 ; LOCP-2 CR MCC ;	water levels checking is done. , ENSURED AUTO OPERATION OF PUMPS.