



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/08/2025

Shift: C

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO11 belt	Tripp occurred due to over load found MPCB acted due to duck sheet jamming	Reset done	02:00:00	02:05:00	02.50am to 0.55am :04.00am to 04.05am
2	OHP	CO11 belt	ZSS acted due to probe loose	Probe tightened then ok	02:20:00	02:30:00	
3	OHP	Stacker on CO7A	Left boom luffing not working	Wrong complaint	23:00:00	23:10:00	
4	OHP	BRC on CO30	CT not working found Ct cabin side limit switch struck	Released then ok	01:00:00	01:20:00	
5	OHP	CO34	Thermal over load acted due to material jamming	Reset done	01:00:00 01:10:00	01:05:00 01:15:00	
6	OHP	BRC on CO28	CT not working found emergency PB acted	Released	03:00:00	03:20:00	
7	OHP	co29	oLR ACTED	Reset done	02:15:00	02:23:00	03.55AM TO 04.00AM
8	OHP	BRC on CO31	LT not working found M6 motor tripped	Reset done	03:00:00	03:15:00	
9	OHP	WOBR on CO29	Slew not working drive tripped	reset done	03:10:00	03:30:00	
10	OHP	BRC on CO30	LT not working found LT drive tripped	Reset done	04:00:00	04:15:00	04.35am to 04.50am
11	OHP	CO67	OLR acted at DMPR	Reset done	03:25:00	03:45:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/08/2025

Shift: C

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	OHP	CO38 B	CJD not working	Control supply ok	04:25:00	04:40:00	informed to instrumentation
13	CHP	SCR4 on CC33	Luffing was not working due to filter clog 3 found cable loose bit not comming * LT not working End limit worked	*Tightened then ok * end limit bypassed and reversed then ok	23:20:00	23:40:00	
14	CHP	CC34	Yard motor over load tripped	Reset done	23:35:00	23:45:00	
15	CHP	SCR3 on CC40	BC not running found motor over load trip	Reset done	02:30:00	02:40:00	
16	CHP	SCR2 on CC34	LT not working found PCRD cable over tension limit acted	OT limit released then ok	02:40:00 03:55:00	03:00:00 04:10:00	
17	CHP	SCR2 on CC34	TUL CJS kept in ckt	In ckt	04:20:00	04:20:00	
18	CHP	CC114	motor tripped on over load	Reset done	02:05:00	02:15:00	
19	CHP	CC51	MPD tripped on olr stopped feeding conveyor	Reset done	01:50:00	01:55:00	
20	CHP	CC130	stopped on ZSS found belt snap at drive end	informed to operation and mechanical	05:10:00	05:10:00	
21	CHP	Cc54	Motor tripped on olr due to over material feeding	Informed to operation Reset done	23:25:00	23:30:00	12.15am to 12.20am
22	WT	CP3	Not moving found communication problem	POE to modem cable was replaced then ok	23:00:00	00:30:00	
23	IOSA	TBS	PCRD over tension acted	Released	00:00:00	00:05:00	