



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO-31`	B/W-1 not running	OLR acted.Reset done	02:50:00	03:00:00	
2	OHP	CO-26	Reported tripped	OLR acted.Reset done	03:25:00	03:35:00	
3	OHP	CO-70	ZSS acted	Over material on belt.Belt moving slowly	04:30:00	05:00:00	Informed to operation
4	CHP	Cc-104 SCR-7	LT not taking place	Wrong complaint	02:30:00	02:40:00	
5	CHP	Cc-51	MPD tripped	Reset done(9 times)	23:30:00	04:00:00	