



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/07/2025

Area: IOSA

Equipment	Job
OC-4A,5A,6A,7A,9A,11A CONVEYORS	FIELD DEVICES FEEDBACK CHECKING DONE.
INSPECTION	INSPECTION DONE ON ZSS CAGE ,PROBE AND MODULE OF TBS,OC-9A,11A,19A,21A
OJH-9A	PPM DONE ON ELECTRICAL HOIST
CHUTE VIBRATORS	OC-16A,17A,18A,19A,21A OTT-1A,OC-7B and OC-13A CHUTE VIBRATORS WORKING AND OLR SETTING CHECKED.
MISC	OC-9A, 11A WELDING SOCKETS MAINTENANCE DONE.
BRC	HARROW BRAKE PANELS KEPT IN PLACE AFTER PAINTING.