



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 06/10/2025

Area: IOSA

Equipment	Job
1-142LC# 2 PLC	CHECKED THE 110V INTERROGATION VOLTAGES FROM SOURCES AND MCB CONDITION
LnT WOBR	SLEW LIMITS AND LUFFING LIMITS MODIFICATION IS IN PROGRESS.
TRANSFER CAR	PANEL MAINTENANCE DONE.
COMPRESSOR HOUSE	LIGHTING DEFECTS RECTIFIED AND SUFFICIENT LIGHTING PROVIDED.
OC-7C	REPLACED DEFECTIVE POWER CONTACTOR AND CHECKED HEALTHINESS AFTER REPLACEMENT.
OC-16A	RECTIFIED THE PULLCORD SWITCHES OF LEFT MIDDLE AND RIGHT MIDDLE. OPERATED AND FEEDBACK CHECKED IN PLC AND OPERATING SYSTEM AND GIVEN CLEARANCE.
OC-21A	PPM DONE ON MOTOR AND FIELD DEVICES.