



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/06/2025

Shift: C

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO6A	LT NOT TAKING PLACE PCRD POWER MCB TRIP	MADE ON	23:30:00	23:50:00	PCRD to be checked in G shift
2	OHP	TBS ON CO 5A	LEFT LUFF NOT TAKING PLACE POWER MCB TRIP	MADE ON	23:00:00	23:20:00	
3	OHP	TBSON CO 19	LEFT LUFF NOT TAKING PLACE POWER MCB AUX BLOCK PROBLEM	BY PASSED	02:00:00	03:00:00	
4	CHP	CC 102	C/S ACTED DUE TO CHUTE JAMMING	INFORMED TO OPERATION	00:45:00	01:25:00	
5	CHP	CC 117	OLR ACTED	RESET	23:30:00	23:40:00	
6	CHP	CC54	OLR ACTED	RESET	02:30:00	02:40:00	
7	CHP	CC 111 S3	pending from B shift, 2 no of HT fuse blown in Isolator	PCRD HT coupler open d/e side and slip ring side also open cable, meggering done found two phase grounded megger value zero	22:20:00	00:40:00	inform DNW satyanarayana and ramana,
8	CHP	CC 32 SCR 5	B/W not rotating, checked in PLC all OK O/p cmd ok, o/p fuse blown of PLC R/i/o	fuse replaced ckt checked, xmd card side input o/p both came	02:00:00	03:30:00	mechanical problem, even after pressing solenoid manually B/W not rotating, informed mech @ 2.40 AM



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/06/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
9	WT	OP 1	BREAKER TRIP	MADE ON	01:50:00	02:15:00	