



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/11/2025

Area: OHP

Equipment	Job
transfer car	ppm is done
om-9,10,lc-6	mcc illumination is improved.
co-41a,42a,43a	field devices ppm is done.
JH O-14, bpc-1, bpc-2,27a,30a,	hoists ppm is done
co-33a,34a,35a,36a,rco-1a,	cjd ppm is done
co-66,69	motor and panel side ppm is done.
ocr to hvmmc-1 ofc cable	ofc cable is laid from lc4 slope area to hvmmc-1 and jointed, shifted redundant communication via this new cable.