



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 22/08/2025

Area: WT

Equipment	Job
O T Complex	Bay area lighting improved 2 nos 350W and 2nos 300W LED fittings replaced
CT 1 and 2 series	Panel side ppm done
OT 5	All limit switches and field wires checked,found OK all kept in circuit
Mis	37 KW pusher motor sent ERS
LC 10A	Ground s/s panel maintenance done for CP1 and 3
OP 2	After rake maintenance done