



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/04/2025

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO33M	OLR ACTED	RESET	00:00:00	00:15:00	
2	OHP	BRC ON CO28	B/WNOT RUNNING JAMMING	INFORMED TO OPERATION	03:30:00	03:45:00	
3	OHP	BRC ON CO 28	B/C STOPPING TARGET AND PROBE DAMAGED	INFORMED TO A SHIFT	05:20:00	05:45:00	
4	OHP	CO 111 (B)	mpcb trips	made it on	03:00:00	03:10:00	
5	CHP	cc 32 scr 5	LT not working,PCRD OT acted	OT released	23:10:00	23:30:00	
6	CHP	CC 111 R1	B/C not running,communication problem,b/c OLR acted, contactor problem	LT done towards transfer car side,OLR reset,contactor tip open and contact clean	03:00:00	04:10:00	
7	CHP	CC 31 S3	b/c mpr trips	reset it done	03:30:00	03:40:00	
8	CHP	CC 22	OLr acted	reset it done	04:25:00	04:30:00	