



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/05/2025

Incharge(s): Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35	OLR acted	reset done	06:45:00 08:15:00	06:55:00 08:25:00	
2	OHP	WOBR on CO 26	No drive running	Down limit acted, reset done	07:00:00	07:20:00	
3	OHP	CO 16	BRS to be bypassed	Bypassed as per operation request, in module	10:15:00	10:20:00	
4	OHP	TBS on CO 23	LT not taking place	PCRD overtension acted, released	12:40:00	12:55:00	
5	CHP	CC 33, SCR 4	LT not working (from C shift)	Operator cabin mains ON , fault reset done. Then LT working	06:00:00	06:15:00	
6	CHP	CC 32	BRS to be bypassed	Bypassed a. Bypassed as per operation request .	07:00:00	08:30:00	Again kept in circuit
7	CHP	CC 112 , SCR 8	Slewing not working	Slew brake pressure sensor switch problem. Switch interchanged from standby panel by instrumentation	08:45:00	11:45:00	
8	CHP	CC 125	Overload acted	reset done	13:20:00	13:25:00	
9	CHP	CC 54	Overload acted	reset done	09:35:00 11:00:00	09:40:00 11:05:00	
10	CHP	CC 104 , SCR 9	Slew not working	Overload tripped , reset done	13:20:00	13:40:00	
11	WT	OP 9	Not moving due to Reverse end limit acted	Limit released , then ok	11:55:00	12:05:00	