



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 13/07/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 37A	STOPPING ON ZS CAGE STUCK UP	ZS CAGE REPLACED	09:30:00	09:45:00	
2	OHP	TBS ON CO 21	LEFT B/C STOPPING ON ZS PROBE DAMAGED	ZS PROBE REPLACED	10:30:00	10:45:00	
3	OHP	CO 84	OLR ACTED	RESET	08:40:00	08:50:00	
4	OHP	BRC ON CO 34	B/W S NOT RUNNING CP 1 TRIP	RESET	12:10:00	12:30:00	
5	CHP	cc 32 scr 5	B/C STOP in ZSS,cage problem	ZSS cage replaced	07:20:00	07:30:00	
6	CHP	CC 38 SCR3	b/c stop in ZSS,cage and module problem	ZSS cage and module replaced	08:00:00	08:15:00	
7	CHP	CC 105 SCR 10	b/c not running,zss acted,coal stucked in ZSS cage,machine at tail end and scr 9 inbetween CCR	zss cage made free and LT done than ok	10:55:00	11:10:00	
8	CHP	CC 105 SCR 10	B/C not running,control mcb trip	control mcb made on	11:35:00	11:50:00	
9	CHP	CC 114	OLR ACTED	RESET	07:30:00	07:40:00	DUE TO MATERIAL OVER LOAD
10	CHP	CC 131	OLR ACTED(3TIMES)	RESET	08:10:00	08:15:00	
11	CHP	CC 54	OLR ACTED(2TIMES)	RESET	08:10:00	08:30:00	
12	CHP	CC 58	OLR ACTED	RESET	08:50:00	09:10:00	
13	CHP	cc 112	D/E CJS not healthy probe touched body	probe adjusted	12:55:00	13:10:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 13/07/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 18	cjs acted,	sensor cleaning done	07:00:00	07:10:00	
15	CHP	CC 25	mech BRS acted	informed mech	07:30:00	07:45:00	
16	CHP	CC 34 SCR 2	LT not working, PCRD OT acted	OT released	13:10:00	13:20:00	