



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/02/2026

Incharge(s): Amit Roy

Shift: C

| Sl No | Area | Equipment | Problem          | Action   | From     | To       | Remarks                 |
|-------|------|-----------|------------------|--|----------|----------|-------------------------|
| 1     | OHP  | VF-19     | Reported tripped | M-1 OLR acted.Reset done                           | 03:00:00 | 03:10:00 | Due to material jamming |
| 2     | OHP  | Cc-201    | Reported tripped | OLR acted.Reset done                               | 01:30:00 | 01:45:00 |                         |
| 3     | CHP  | Cc-32 S-3 | B/C not running  | OLR acted.Reset done                               | 00:55:00 | 01:05:00 |                         |
| 4     | CHP  | Cc-25     | ZSS acted        | Cage stuck with material.Made free and tested okay | 00:00:00 | 00:10:00 |                         |
| 5     | CHP  | Cc-58     | Reported tripped | D-2 motor OLR acted.Reset done                     | 23:30:00 | 23:45:00 |                         |
| 6     | CHP  | Cc-51     | MPD tripped      | Reset done(7 times)                                | 03:00:00 | 05:00:00 |                         |