



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	OLR ACTED	RESET DONE	07:50:00	08:00:00	
2	OHP	CO-10A	OLR ACTED	RESET DONE	06:40:00	06:50:00	
3	OHP	BRC ON CO-33-M	CT NOT TAKING PLACE FOUND CONTROL MCB TRIP	CONTROL MCB MADE ON	07:50:00	08:10:00	
4	OHP	CO-26	TRIPPED ON OLR	RESET DONE	10:30:00	10:40:00	
5	OHP	CO-33M	OLR ACTED	RESET DONE	11:40:00	11:50:00	
6	CHP	CC-51	MPD TRIP (2TIMES) FEEDING CONVEYOR STOP	RESET DONE	09:00:00 10:15:00	09:10:00 10:20:00	
7	CHP	CC-131	OLR ACTED	RESET DONE	12:55:00	13:00:00	
8	CHP	CC-125	OLR ACTED (2TIMES)	RESET DONE	08:36:00 10:10:00	08:40:00 10:15:00	
9	CHP	CC-201	TRIPPED ON OLR (2TIMES)	RESET DONE	09:20:00 09:30:00	09:25:00 09:45:00	
10	CHP	CC-203	OLR ACTED (2TIMES)	RESET DONE	09:20:00 10:30:00	09:30:00 10:40:00	
11	CHP	CC-33 SCR-5	REPORTED B/C NOT RUNNING FOUND SIGNAL PROBLEM	LT MOVE FWD THAN OK	10:45:00	11:30:00	
12	IOSA	OC-7B	REPORTED FAIL TO START	CONTROL SUPPLY RE-CYCLED THAN OK	13:15:00	13:25:00	