



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/11/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	REPORTED NOT HEALTHY FOUND GLASS FUSE BLOWN IN CJB	GLASS FUSE REPLACED THAN OK	10:30:00	10:45:00	
2	OHP	VF-1A	M-1 OLR ACTED	RESET DONE	11:45:00	11:55:00	
3	CHP	CC-51	MPD TRIP (3TIMES) FEEDING CONVEYOR STOP	RESET DONE	07:40:00 09:05:00 10:30:00	07:45:00 09:10:00 10:40:00	
4	CHP	CC-131	OLR ACTED (3TIMES)	RESET DONE	09:50:00 10:55:00 13:10:00	09:55:00 11:00:00 13:15:00	
5	CHP	CC-54	OLR ACTED (2TIMES)	RESET DONE	10:50:00 11:25:00	11:00:00 11:30:00	
6	CHP	CC-33 SCR-5	PCRD GUIDE PROBLEM FENDING FROM N SHIFT	PCRD GUIDE PROBLEM RECTIFIED BY MECHANICAL THAN PCRD CABLE PROPER LAYING WAS DONE	06:30:00	07:20:00	
7	CHP	CC-47	REPORTED HEALTHY NOT RUNNING FOUND K1 RELAY STUCK UP IN DRIVE PENAL	RELEASED THAN OK	07:45:00	08:10:00	
8	CHP	CC-34 SCR-1	LUFF NOT WORKING MPD TRIP	RESET DONE	09:15:00	09:30:00	
9	CHP	CC-43	STOPPING ON ZSS FOUND PROBE GOT CUT	PROBE CABLE JOINT DONE THAN OK	10:20:00	10:30:00	
10	CHP	CC-112 SCR-8	REPORTED SLEW NOT WORKING FOUND OIL LOW LEVEL INFORMED TO MECHANICAL	OIL TOP UP BY MECHANICAL THAN OK	11:25:00	11:45:00	