



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/11/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS-2	OLR ACTED (2TIMES)	RESET DONE	06:30:00 11:00:00	06:40:00 11:10:00	
2	OHP	BRC ON CO-30	B/C NOT RUNNING FOUND OLR ACTED	RESET DONE	08:10:00	08:25:00	
3	OHP	CO-67	TRIPPED ON OLR	RESET DONE	09:00:00	09:15:00	
4	OHP	TT-4	REPORTED NOT MOVE FOUND MPCB TRIP	RESET DONE	12:10:00	12:25:00	
5	OHP	CC-17	STOPPING ON ZSS	SENSITIVE ADJUSTED THAN OK	10:05:00	10:15:00	
6	OHP	CO-29	OLR ACTED	RESET DONE	13:30:00	13:40:00	
7	CHP	CC-37	REPORTED NOT RUNNING	POWER RE-CYCLED THAN OK	07:35:00	07:45:00	
8	CHP	CC-201	TRIPPED ON OLR	RESET DONE	06:33:00	06:40:00	
9	CHP	CC-125	OLR ACTED	RESET DONE	10:20:00	10:30:00	
10	CHP	CC-105	STOPPING ON ZSS CHECKED AND FOUND NO PROBLEM	CLEARANCE GIVEN THAN OK	08:40:00	08:50:00	
11	CHP	CC-17	REPORTED STOPPING ON ZSS FOUND ZSS PROBE PROBLEM	ZSS PROBE REPLACED THAN OK	07:45:00	08:15:00	
12	CHP	CC-131	OLR ACTED	RESET DONE	07:30:00	07:35:00	
13	CHP	CC-51	MPD TRIP (10TIMES) FEEDING CONVEYOR STOP	RESET DONE	07:40:00	13:30:00	
14	CHP	CC-54	OLR TRIP (2TIMES)	RESET DONE	07:55:00	08:10:00	
15	WT	CP-2	REPORTED NOT MOVE FOUND COMMUNICATION PROBLEM	POWER RE-CYCLED IN LC-10A	06:30:00	06:45:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	WT	OP-3	REPORTED NOT MOVE FOUND DRIVE -1 TRIP COUPLING TIME	RESET DONE	12:00:00	12:15:00	
17	WT	OP-3	NOT MOVE 5A-1 ROTAR CONTACTOR STUCK UP	FREE IT AND CLEANING DONE THAN OK	12:25:00	12:45:00	