



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 21/01/2026

Area: OHP

Equipment	Job
locp-2 crushers	For CR-1 and CR-2 ht fuse fail contact is taken and taken to io rack using a spare core. to be interlocked.
co-50,53,56	cjd ppm is done ; co-50 zss cage is replaced.
daybins-1 bunker level sensors	ppm is done
co-33a,35a,37a	safety devices ppm is done
cr-2 panel	contactor checking is done using coil controller.
1-14lc3 incomer 1 voltas breaker	maintenance is done and breaker ON mechanism rectified.
co-5,8,11,3a ; co-8a	motor and panel side ppm is done