



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/06/2025

Area: WT

Equipment	Job
OP 8	Drive 1(M6) checked found motor mis alignment (to be done)
CC 9 side	lighting problem rectified(cable loose in LDB)
OP 4	panel and motor side ppm done
OP 2	panel and motor side ppm done
OP2,4,7 and 10	after rake maintenance done