



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/12/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 16A	healthy stop,jamming	move in local than ok	00:30:00	00:45:00	not electrical delay
2	OHP	BRC on CO 34	BW not running,control cable in DMPR loose connection	tightened	00:40:00	00:55:00	
3	OHP	CO 26	OLR acted	reset	01:25:00	01:35:00	
4	CHP	CC 51	mpd tripped	reset	01:25:00	01:30:00	
5	CHP	cc 52	mpd tripped	reset	01:40:00	01:45:00	
6	CHP	CC 34 SCR1	pcrd cable	winding done	22:40:00	22:50:00	
7	CHP	CC 31 SCR4	B/w area focus lighting problem	temporary lighting provided	23:43:00	00:05:00	to be checked in G shift
8	CHP	CC 39 s1	LT not working, potentiometer fault	knob adjusted Lt given	23:00:00	23:16:00	refer to G shift
9	CHP	CC 105 SCR10	LT not working,PCRD cable problem	PCRD cable proper winding done	03:30:00	04:20:00	guide problem
10	CHP	CC 219FG	light not working,MCB tripped	made it on	01:10:00	01:15:00	
11	WT	OT 4	D1 tripped in pgf4 fault	reset	02:30:00	02:35:00	
12	WT	OC 1A(B)	OLr acted	reset	04:55:00	05:00:00	
13	IOSA	BRC	no power,main contactor not on,due to emergency operated	emergency released	22:30:00	22:40:00	