



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/01/2026

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|------------------------|---|------------------|----------------------|----------------------|---------|
| 1 | OHP | CO 34 | OLR ACTED | RESET | 19:20:00 19:35:00 | 19:25:00 19:40:00 | |
| 2 | OHP | CO 25 | OLR ACTED | RESET | 20:35:00 | 20:45:00 | |
| 3 | OHP | TBS ON CO 20 LT | MPCB TRIP | MADE IT ON | 16:45:00 | 17:00:00 | |
| 4 | OHP | DAYBINS , RSCO 10A RED | INCOMER 1 TRIPPED IN NEW LC3 DUE TO UNDER VOLTAGE FAULT | RESET MADE IT ON | 16:55:00 | 17:05:00 | |
| 5 | CHP | CC 51 | FEEDING CONV MPD ACTED | RESET | 15:00:00 | 18:30:00 | 5 TIMES |
| 6 | CHP | CC 52 | FEEDING CONV MPD ACTED | RESET | 15:00:00 | 21:50:00 | 5 TIMES |
| 7 | CHP | CC 54 | OLR ACTED | RESET | 15:05:00 | 15:15:00 | |
| 8 | CHP | CC 132 | OLR ACTED | RESET | 16:05:00 21:45:00 | 16:15:00 21:55:00 | |
| 9 | WT | OT2 | DRIVE 2 TRIPPED ON PGF1 FAULT | RESET | 16:15:00 | 16:20:00 | |
| 10 | WT | OT4 | DRIVE 1 TRIPPED PGF4 FAULT | RESET | 16:55:00 | 17:00:00 | |
| 11 | WT | OP5 | DRIVE 5 OLR ACTED DURING COUPLING TIME | RESET | 14:20:00 | 14:30:00 | |
| 12 | WT | OT2 | DRIVE 2 TRIPPED ON PGF4 FAULT | RESET | 21:20:00 | 21:30:00 | |