



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/11/2025

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 57	PC	KEPT IN CIRCUIT	07:00:00	09:20:00	
2	OHP	CO 26	OLR ACTED	RESET	07:50:00	08:00:00	
3	OHP	CC 29	OLR ACTED	RESET	07:00:00 12:00:00	07:10:00 12:05:00	
4	CHP	SCR 4 ON CC 31	PCRD CABLE FELL DOWN	WINDING DONE	06:45:00	07:00:00	
5	CHP	SCR 3 ON CC 35	SLEW OIL LEVEL LOW	INFORMED TO MECH	07:40:00	07:50:00	
6	CHP	CC 31	OLR ACTED	RESET	11:00:00	11:05:00	
7	CHP	CC 54	OLR ACTED	RESET	11:30:00	11:35:00	
8	CHP	CC131	B/S ACTED	RELEASED	11:00:00	11:10:00	
9	CHP	CC 131	zss stone got stuck	REMOVED	12:30:00	12:45:00	