



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/10/2025

Incharge(s): M Kailash

Shift: B

| Sl No | Area | Equipment    | Problem  | Action  | From                 | To                   | Remarks |
|-------|------|--------------|--|---|----------------------|----------------------|---------|
| 1     | OHP  | co-29        | Overload acted   | Reset done  | 20:10:00             | 20:20:00             | .       |
| 2     | OHP  | TBS on CO-7A | Right luffing up not working   | found limit switch tied with rope. limit switch made free and given clearance | 17:20:00             | 17:30:00             | .       |
| 3     | OHP  | co-19        | Reported not running in Local mode   | Found EM-Stop NC block contact problem. Rectified                             | 17:05:00             | 17:15:00             | .       |
| 4     | OHP  | VF-10        | Motor not running. Found cable rubbing at motor TB gland                           | Proper packing and taping provided and tested ok                              | 21:15:00             | 21:40:00             |         |
| 5     | OHP  | VF-9A        | Chute vibrator motor not running. Found motor Y phase got cut inside the motor TB. | Cable re jointing done and made ok  | 21:50:00             | 22:00:00             |         |
| 6     | CHP  | cc-110       | zss complaint  | checked module and probe and found ok.  | 19:30:00             | 19:45:00             | .       |
| 7     | CHP  | cc-29        | overload acted   | Reset done  | 17:30:00             | 17:40:00             | .       |
| 8     | CHP  | CC-51        | MPD tripped on overload to stop feeding conveyor ( 6 times)                        | Reset done  | 15:35:00             | 17:15:00             | .       |
| 9     | CHP  | CC-114       | Overload tripped   | Reset done  | 17:50:00             | 18:00:00             |         |
| 10    | CHP  | CC-131       | Overload trip  | Reset done  | 19:35:00<br>21:10:00 | 19:40:00<br>21:15:00 |         |
| 11    | CHP  | CC-54        | Overload acted   | Reset done  | 20:50:00<br>21:00:00 | 20:55:00<br>21:05:00 |         |
| 12    | CHP  | CC-114       | ZSS acted.   | Checked and found belt snapped. Informed to operation                         | 18:15:00             | 18:20:00             |         |
| 13    | CHP  | SCR-4        | Luffing not working. Found oil level low.  | Informed to mechanical. After oil filling, checked OK                         | 15:05:00             | 15:15:00             |         |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/10/2025

Incharge(s): M Kailash

Shift: B

| Sl No | Area | Equipment | Problem  | Action   | From     | To       | Remarks                          |
|-------|------|-----------|--|--|----------|----------|----------------------------------|
| 14    | WT   | AF-4      | Drive tripping on un balance fault.                | Motor decoupled and checked. Still drive is tripping. Motor meggered and found winding fault | 19:00:00 | 22:30:00 | Motor changing is under progress |
| 15    | WT   | SCO-1A    | Carriage drive not moving. Overload acted          | Reset done   | 16:00:00 | 16:10:00 |                                  |
| 16    | WT   | OT-3      | Not rotating. Found FWD limit not closing properly | Made ok  | 17:10:00 | 17:20:00 |                                  |