



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/01/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS-1A	Reported tripped	OLR acted.Reset done	19:15:00	19:20:00	
2	OHP	TBS on CO-5A	LT not taking place	S/S found in local.KEPT in auto	19:00:00	19:20:00	
3	OHP	CO-25	Reported tripped	OLR acted.Reset done	19:00:00	19:30:00	
4	OHP	CO-33M	Reported tripped	OLR acted.Reset done	20:00:00	20:05:00	
5	OHP	CO-29	Reported tripped	OLR acted.Reset done	20:40:00	20:45:00	
6	CHP	CO-26	Reported tripped	OLR acted.Reset done	17:00:00	17:10:00	
7	CHP	CC-31 SCR-4	LT not taking place	M-9 tripped.Reset done	16:35:00	16:50:00	
8	CHP	CC-47	Reported fail to start	Checked and found aux block loose in Relay.Rectified	18:00:00	18:30:00	
9	CHP	CC-51	MPD tripped	Reset done(13 times)	14:40:00	21:40:00	
10	CHP	CC-51	Reported tripped	OLR acted.Reset done(2 times)	16:40:00	18:15:00	