



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/05/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR ACTED	RESET	08:45:00	09:00:00	
2	CHP	CC13	STOPPING ON ZS	ZS PROBE GAP ADJUSTED	08:40:00	08:50:00	
3	CHP	cc-34 scr-2	LT NOT WORKING	OVER TENSION ACTED ... RELEASED	13:10:00	13:20:00	
4	CHP	CC-40 SCR-9	LT NOT WORKING	DRIVE TRIPPED RESET	13:35:00	13:45:00	
5	CHP	CC-35 S-1	LT NOT WORKING	DRIVE TRIPPED ... RESET DONE	09:35:00	09:45:00	
6	CHP	CC-31 R-1	BC NOT RUNNING	C/S AND ZSS FUSE BLOWEN ... CONTROL MCB IN OFF CONDITION. FUSE CHANGED ... MCB MADE ON	06:45:00	07:15:00	
7	CHP	CC-111 S-3	BC NOT RUNNING , SLEW ALSO NOT RUNNING	MCCB TRIPPED ...MADE ON ... SLEW OLR ACTED .. RESET DONE	06:20:00	07:00:00	
8	WT	CP2	ROTAREY CONTACTOR TIMER NOT PICK UP	TIMER CNTACT BYPASSED	08:45:00	09:15:00	
9	WT	OC1A	TRIPPED ON OVER CURRENT	RESET DONE	11:00:00	11:15:00	DUE TO JAMMING
10	WT	OP5 OP6	NO POWER I/C TRIPPED IN LC 2B	MADE ON THAN OK	11:15:00	11:30:00	