



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/02/2026

Area: OHP

Equipment	Job
co-37a,68,69	receiving chute vibrators working status checked, found ok.
mechanical brs	preparation is under progress.
co-58 pullchord	working status checked,
JH o-5, 3b,4a gallery	lighting circuit rectified and lamps replaced.
ocr telecom room	Cleaning needs to be done, sump pump removed and shifted to locp2 crusher aux mcc.
1-141lc3 battery room	room cleaned, lighting is rectified, old batteries shifted aside and newer ones were shifted to battery room.
CO-78,85,87; rco-1a	MOTOR AND PANEL SIDE ppm is done
IO-9	ht isolator panel maintenance is being done. Moisture is observed, cleaning is under progress.