



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/10/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-10A	Reported tripped	OLR acted.Reset done	07:05:00	07:15:00	
2	OHP	TBS on CO-7A	Reported Right boom not running	ACB tripped due to material jamming in chute	09:35:00	09:50:00	Material cleared and tested okay
3	OHP	TBS on CO-7A	LT not taking place	M2 MPCB tripped.Motor checked and found burnt.M2 kept out of circuit	10:00:00	10:20:00	M2 motor to be changed
4	CHP	CC-54	Reported tripped	OLR acted.Reset done	11:25:00 11:45:00	11:35:00 11:55:00	
5	CHP	CC-51	Reported tripped	MPD acted(6 times).Reset done	09:05:00	12:30:00	Tripped at 9 .05,9.25,11.30,11.45, 12.15,12.30pm
6	CHP	CC-38 SCR-6	Reported Slew not moving	Limit acted.Released and tested okay	07:30:00	07:45:00	
7	CHP	CC-33 SCR-5	Reported LT not taking place	Drive tripped.Reset done and tested okay	07:30:00	07:40:00	
8	CHP	CC-36 SCR-1	Reported Luffing not working	OLR acted.Reset done and tested okay	07:45:00	08:00:00	
9	CHP	CC-28(B/D)	Reported tripped	OLR acted.Reset done(2times)	12:30:00	12:40:00	
10	WT	OC-1A	Reported tripped	OLR acted.Reset done	07:15:00	07:30:00	
11	WT	SC0-1A	Reported not running	Contactorauxiliary block opened.Rectified and tested okay	12:10:00	12:30:00	
12	IOSA	TBS	CJD problem	CJD probe changed from left to right chute	10:00:00	11:00:00	