



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 14/07/2025

Incharge(s): V Balaji Naik

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO12 carriage drive	OLR acted	Reset done	16:30:00	16:36:00	
2	OHP	CO27A	BRS kept in ckt on operational request	In ckt	17:30:00	17:35:00	
3	OHP	WOBR on CO29	BW not working due to over load	Reset done	17:45:00	18:00:00	
4	OHP	CO67	ZSS not healthy due to module mal functioning	Module replaced then ok	18:00:00	18:30:00	
5	CHP	CC113	ZSS acted found head end jamming	Informed to operation	19:00:00	19:05:00	
6	CHP	SCR2 on CC34	LT not working found OT limit acted	Limit released then ok	16:20:00	16:35:00	
7	CHP	SCR5 on CC32	Boom conveyor not running found MCB tripped	Reset done	17:35:00	17:50:00	
8	CHP	CC 201 and CC203 (LC04)	Not healthy over load trip	Reset done	21:00:00	21:05:00	
9	CHP	SCR4 on CC33	SCR4 BC middle area 120w light fixed	Light fixed	19:45:00	20:00:00	