



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 09/07/2025

Area: WT

| Equipment | Job  |
|-----------|--|
| OP 9      | Modification for drive bypass and drive in circuit option provided in SCADA                  |
| CT 1      | Hooper area one no 200W LED replaced and 2 nos Tubes replaced in coal scooter shed           |
| OT 5      | New 'SICK' Anti collision device installed at out haul side wagon sensor for testing purpose |
| OP 2      | panel and motor side ppm done ,D5 OLR replaced and kept in circuit                           |
| OP4 and 6 | after rake maintenance done  |