



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 04/02/2026

Area: WT

Equipment	Job
OT 3	M2 ,burnt motor coupling removed and sent to E R S
OP 5	Track lifting done by railways @ parking zone
CP 3 jobs	Control Desk side wiring done ,trolley line inspection done from C D found signals OK
CP 1,2 and 4	After rake maintenance done
OP 1,4,5 and 8	After rake maintenance done